

Препоръчителни минимални дебелини на тръбна изолация на закрито

D,mm	Дебелина на стената, mm								
	51-100°C	101-150°C	151-200°C	201-250°C	251-300°C	301-350°C	351-400°C	401-450°C	451-500°C
15	30	30	40	50	70	80	100	120	130
20	30	30	40	50	70	90	100	120	140
25	30	30	40	60	70	90	110	130	150
32	30	30	40	60	70	90	110	130	150
40	30	30	40	60	80	100	120	140	160
50	30	30	50	60	80	100	120	140	170
65	30	40	50	70	80	110	130	150	180
80	30	40	50	70	90	110	130	160	180
100	30	40	50	70	90	120	140	160	190
125	30	40	50	70	90	120	150	170	200
150	30	40	60	80	100	130	150	180	210
200	30	40	60	80	100	130	160	190	220
250	30	40	60	80	110	140	170	200	230
300	30	40	60	90	110	140	170	210	240
350	30	40	60	90	110	150	180	210	250
400	30	40	60	90	110	150	180	220	250
450	30	40	60	90	120	160	190	220	250
500	30	40	60	90	120	160	190	220	260