

препоръчителни минимални дебелини на тръбна изолация на открито

D,mm	Дебелина на стената, mm								
	51-100°C	101-150°C	151-200°C	201-250°C	251-300°C	301-350°C	351-400°C	401-450°C	451-500°C
15	30	40	50	60	70	80	100	110	130
20	30	40	50	60	70	90	100	120	130
25	30	40	50	60	80	90	100	120	140
32	30	40	50	70	80	100	110	130	150
40	30	40	60	70	80	100	110	130	150
50	30	50	60	70	90	100	120	140	160
65	30	50	60	70	90	110	130	150	170
80	30	50	60	80	90	120	130	160	180
100	40	50	70	80	100	120	140	170	190
125	40	50	70	80	100	130	150	170	200
150	40	50	70	90	110	130	150	180	210
200	40	50	70	90	110	140	160	190	220
250	40	60	70	90	120	140	170	200	230
300	40	60	80	100	120	150	170	200	230
350	40	60	80	100	120	150	180	210	240
400	40	60	80	100	120	150	180	210	240
450	40	60	80	100	120	160	190	220	250
500	40	60	80	100	130	160	190	220	250
600	60	80	100	120	150				
700	100	120							